

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr  
1 Lysander Drive, Northfields Industrial Estate,  
Market Deeping,  
Peterborough, PE6 8FB  
England

Measuring instrument A static **Active Electrical Energy Meter**  
Type : E450 ZMXi3x0CP S3 (5363A&B)  
Manufacturer's mark or name : Landis + Gyr  
Reference voltage : 3x220/380 V ... 3x240/415 V  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : A or B  
Environment classes : M2 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10613 revision 8;
- Documentation folder T10613-4.

Valid until 28 July 2024

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
14 February 2019

  
C. Oosterman  
Head Certification Board