


| | |
|----------------------|---|
| Issued by | NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to: |
| Manufacturer | Holley Technology Ltd. No. 181 Wuchang Avenue, Yuhang District Hangzhou 310023 P.R. China |
| Measuring instrument | A static Active Electrical Energy Meter Type : DTSD545 Manufacturer's mark or name : Holley Reference voltage : 3x 230/400 V Reference current : 5 or 10 A Destined for the measurement of : electrical energy, in a three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +55 °C Further properties are described in the annexes: – Description T10659 revision 1; – Documentation folder T10659-2; |
| Valid until | 4 June 2025 |
| Remarks | This revision replaces the earlier version, including its documentation folder. |

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
7 April 2017



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.