





Number T10678 revision 10 Project number 2686102 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV

Pondweg 7

2153 PK Nieuw Vennep

The Netherlands

Measuring instrument A static Active Electrical Energy Meter

Type PRO380

Reference voltage 3x230/400 V Reference current 1.5 A

Destined for the measurement of electrical energy, in a

> - three-phase four-wire network - three-phase three-wire network - single-phase two-wire network

Accuracy class B or C **Environment classes** M1 / E2 Temperature range -25 °C / +70 °C

Further properties are described in the annexes:

- Description T10678 revision 10:

- Documentation folder T10678-7.

Valid until 9 December 2024


Remark This revision replaces the earlier versions, including its documentation

folder.



Issuing Authority





This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party

The designation of NMi Certin B.V. as Notified Body can be verified at http://

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

ec.europa.eu/growth/tools-databases/nando/