


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	WASION GROUP LIMITED No.468 West Tongzipo Road High-Tech Industrial Development Zone 410205 Changsha City, Hunan Province P.R. China
Measuring instrument	A static Active Electrical Energy Meter Type : aMeter300 - direct connected meter (DC) aMeter300 - connected through transformer meter (CT) Reference voltage : 3x 220/380V ... 3x240/415V (DC) 3x 57,7/100V ... 3x240/415V (CT) 3x 100V ... 120V (CT) Reference current : 5 A (DC) 1 A (CT) Destined for the measurement of : electrical energy, in a - Three-phase four-wire network - Three-phase three-wire network Accuracy class : A or B (DC) B or C (CT) Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10704 revision 0; - Documentation folder T10704-1.
Valid until	5 June 2025

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
5 June 2015



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.