

## EU-type examination certificate

Number **T10724** revision 2 Project number 16200677 Page 1 of 1

lssued by Manufacturer	NMi Certin B.V., designated and notified by the Ne conformity modules mentioned in having established that the Measu requirements of Directive 2014/32, Shenzhen Kaifa Technology Co., L 7006 Caitian RD., Futian Dist. 518035 Shenzhen	article 17 of Directive 2014/32 iring instrument meets the app /EU, to:	/EU, after
	P.R. China		
Measuring instrument	A static <b>Active Electrical Energy</b> Type	7 <b>Meter</b> : MA120	
	Manufacturer's mark or name	+ : KAIFA	
	Reference voltage Reference current Destined for the measurement of Accuracy class Environment classes Temperature range	<ul> <li>230 V</li> <li>5 A or 10 A</li> <li>electrical energy, in a <ul> <li>single-phase two-wire</li> </ul> </li> <li>A or B</li> <li>M1 / E2</li> <li>-25 °C / +55 °C</li> </ul>	e network
	Further properties are described ir – Description T10724 revision 2; – Documentation folder T10724-3.		
Valid until	14 December 2025		
Remarks	This revision replaces the earlier ve folder.	ersions, including its document	tation
Issuing Authority	NMi Certin B.V., Notified Body 6 December 2016 C. Oosterman Head Certification Board	number 0122 + + + + + + + + + + + + + + + + + +	
NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl	This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability. The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/enterprise/newapproach/nando/	Reproduction of the complete document only is permitted.	INSPECTION RVA   122