

EU-type examination certificate

Number **T10743** revision 0 Project number 15200667 Page 1 of 1

Issued by Manufacturer	NMi Certin B.V., designated and notified by the Ne conformity modules mentioned in having established that the Measu requirements of Directive 2014/32, BADO Sarl APPT 22 IMM B Salam Centre Angle Bd V et rue med el Qorri	articl Iring i	e 17 of Directive nstrument meets	2014/32/	EU, afte		
	Kénitra 14000 Maroc						
Measuring instrument	A static Active Electrical Energy	Mete	er				
	Туре	÷ ÷	BBT1D (DC) BBT1I (CT)				
	Reference voltage Reference current Destined for the measurement of	+ + + + + + + + + + + + + + + + + + + +	3x230/400 V 5 A electrical energy	v, in a			
	Accuracy class	+ + + + + +	- three-phase for A or B (DC) B or C (CT)		netwo	rk + +	
	Environment classes Temperature range	+ + + +	M1 / E2 -25 °C / +55 °C				
	Further properties are described ir – Description T10743 revision 0 – Documentation folder T10743-1	n the a	annexes				
Valid until	22 April 2026						
+ + + + + + + + + + + + + + + + + + +	• •	+ + +	+ + + + + + + + + + + + +				
Issuing Authority	NMi Certin B.V., Notified Body 22 April 2016 C. Oosterman Head Certification Board	+ + + + + + + + + +	ber 0122 +				
NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl	This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability. The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/enterprise/newapproach/nando/		luction of the complete ent only is permitted.	<mark>ہ</mark>	INSPE RVA	CTION I 122	