





Number T10754 revision 7 Project number 3707498 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Shanghai Fengyilong Electronic Co,.LTD

No.5 Hangdu Road, Hangtou

201316 Pudong

China

Measuring instrument A static Active Electrical Energy Meter

Type DRT-341A, DRT-341D (DC),

DRT-341C (CT)

Manufacturer's mark or name Forlong

Reference voltage 3x230/400 V

Reference current 5 or 10 A (DRT-341A, DRT-341D)

10 A (DRT-341C)

1,5 A (DRT-341C CT, DRT-341D CT)

Destined for the measurement of electrical energy, in a

- three-phase four-wire network

Accuracy class A or B **Environment classes** M1/E2

-40 °C / +70 °C Temperature range

Further properties are described in the annexes:

- Description T10754 revision 7;

- Documentation folder T10754-6.

Valid until 19 July 2026

Initially issued 19 July 2016

Remark This revision replaces the earlier versions.

Issuing Authority

NMi Certin B.V., Notified Body number 0122

28 July 2023

Certification Board

NMi Certin B.V. This document is issued under the provision Thijsseweg 11 that no liability is accepted and that the manufacturer shall indemnify third-party liability.

> The designation of NMi Certin B.V. as Notified Body can be verified at http://

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.







www.nmi.nl

ec.europa.eu/growth/tools-databases/nando/