

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EC, to:
Manufacturer	WASION GROUP LIMITED No.468 West Tongzipo Road High-Tech Industrial Development Zone 410205 Changsha City, Hunan Province P.R. China
Measuring instrument	A static Active Electrical Energy Meter Type : aMeter300-direct connected meter (DC) and connected through transformer meter (CT) Manufacturer's mark or name : Wasion Reference voltage : 3x 220/380V ... 3x240/415V (DC) 3x57,7/100V...3x240/415V (CT) Reference current : 5 A (DC meter) and 1 A (CT) Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network - two-phase three-wire network - single-phase two-wire network Accuracy class : A or B (DC) A or B or C (CT) Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10781 revision 2; - Documentation folder T10781-2.
Valid until	1 September 2026
Remark	This revision replaces the earlier version, including its documentation folder.
Issuing Authority	NMi Certin B.V., Notified Body number 0122 10 October 2017


C. Oosterman
Head Certification Board