

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer EFR GmbH
Nymphenburger Straße 20 b
80335 München
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type : SGM-D

Manufacturer's mark or name : EFR

Reference voltage : 3x230/400 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- single-phase two-wire network

Accuracy class : B or A

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Storage temperature range : -40 °C / +85 °C

Further properties are described in the annexes:

- Description T10794 revision 4;
- Documentation folder T10794-5.

Valid until 22 September 2026

Remark This revision replaces the previous versions, including its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
23 April 2020

Certification Board