

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer ITRON  
1 Avenue des temps modernes  
ZI du Bernais B.P. 23  
86361 Chasseneuil du Poitou  
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : ITE411L3H  
Manufacturer's mark or name : ITRON  
Reference voltage : 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : B or A  
Environment classes : M1 / E2  
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:  
- Description T10797 revision 5;  
- Documentation folder T10797-5.

Valid until 20 September 2026

Remarks This revision replaces the earlier versions, including its documentation  
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
9 November 2018



C. Oosterman  
Head Certification Board

**NMI Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMI Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.