

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Shenzhen Kaifa Technology (Chengdu) Co., Ltd.  
No.1218 Hezuo Rd., Hi-Tech Development Zone (West), Chengdu  
P.R.China.

Measuring instrument A static **Active Electrical Energy Meter**

Type	: MA309M
Reference voltage	: 3x230/400 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10832 revision 3;
- Documentation folder T10832-4.

Valid until 4 October 2026

Remark This revision replaces the previous versions, including its documentation folder.

Issuing Authority

**NMI Certin B.V., Notified Body number 0122**  
16 April 2019

  
C. Oosterman  
Head Certification Board