

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Semax AG  
Riedstrasse 11  
6330 Cham  
Switzerland

Measuring instrument A static **Active Electrical Energy Meter**

Type : AS3000(V) or AS3500(V)

Manufacturer's mark or name : Semax

Reference voltage : 3x230/400V or 3x230V (DC/CT)  
3x58/100V or 3x100V (CT)  
3x63/110V or 3x110V (CT)

Reference current : 5 , 10 or 20 A (DC)  
1, 5 or 10 A (CT)

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : A, B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
– Description T10870 revision 3;  
– Documentation folder T10870-2.

Valid until 26 September 2026

Remark This revision replaces the earlier version, excluding its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
10 December 2020

Certification Board