

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	ISKRAEMECO Energy Measurement Plot No. 1, Pyramids Industrial West Park (Former Zeizenia) 10 th of Ramadan City Egypt
Measuring instrument	A static Active Electrical Energy Meter Type : MT300 - direct connected meter (DC) MT300 or MT800 – connected through transformer meter (CT) Manufacturer's mark or name : ISKRA Reference voltage : 3x 220/380V ... 3x240/415V (DC) 3x 57,7/100V ... 3x240/415V (CT) 3x 100V ... 120V (CT) Reference current : 5 A (DC) 1 A (CT) Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network Accuracy class : A or B (DC) B or C (CT) Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10880 revision 0; - Documentation folder T10880-1.
Valid until	8 September 2026

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
8 September 2016


C. Oosterman
Head Certification Board