

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer MetCom Solutions GmbH  
Marie-Curie-Strasse 19  
D-68219 Mannheim  
Germany

Measuring instrument An **electrical energy meter**

Type : MCS301 and MCS501  
Manufacturer's mark or name : MetCom  
Reference voltage : 3x58/100 V, 3x230/400 V or  
3x58/100 V .... 3x240/415 V or  
3x58/100 V .... 3x277/480 V or  
3x100 V ... 3x240 V or  
3x230V/400V ... 3x415/720V  
3x400/690V (Aux Power)  
Reference current : 1 A or 5 A (CT version)  
5 A or 10 A (DC version)  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- two-phase three-wire network  
- single-phase two-wire network  
Accuracy class : A or B (DC version)  
B or C (CT version)  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T11028 revision 14;  
- Documentation folder T11028-11.

Valid until 16 October 2027

Remark This revision replaces the earlier versions, including for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
13 January 2023

Certification Board