	NMI)	EU-type examination		
				certificate
				Number T11053 revision 3 Project number 3669587 Page 1 of 1
(+	Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity asssessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:		
	Manufacturer	DZT Pondweg 7 2153 PK Nieuw-Vennep The Netherlands		
	Measuring instrument A static Active Electrical Energy Meter		ter	
		Туре	:	6921, 6922, 6923, 6924
		Manufacturer's mark or name	:	DZT
		Reference voltage	:	230 V
		Reference current	:	5 A
		Destined for the measurement of	:	electrical energy, in a - single-phase two-wire network
		Accuracy class	:	A or B
	(-	Environment classes	:	M1 / E2
		Temperature range	:	-40 °C / +70 °C
		Further properties are described in the annexes: – Description T11053 revision 3; – Documentation folder T11053-4.		
	Valid until	24 April 2027		
	Initially issued	24 April 2017		
	Remark	This revision replaces the earlier ve folder.	rsio	ns, including its documentation

Issuing Authority

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

NMi Certin B.V., Notified Body number 0122 13 July 2023

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

