

|                      |  |
|----------------------|--|
| Issued by            | NMi Certin B.V.,<br>designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:  |
| Manufacturer         | Landis + Gyr A.E.<br>78th km National Road Athens-Corinth<br>GR-201 00, Corinth<br>Greece  |
| Measuring instrument | A static <b>Active Electrical Energy Meter</b><br>Type : E450 IDIS ZMXi 3x0 xP xx xx xx . xx S2<br>E450 IDIS ZFXi 3x0 xP xx xx xx . xx S2<br>E450 Non-IDIS ZMX 3x0 xP xx xx xx.xx S2<br>Manufacturer's mark or name : Landis + Gyr<br>Reference voltage : 3x230/400 V or 3x230 V or 230 V<br>Reference current : 5 A or 10 A<br>Destined for the measurement of : electrical energy, in a<br>- three-phase four-wire network<br>- three-phase three-wire network<br>- two-phase three-wire network<br>- single-phase two-wire network<br>Accuracy class : A or B<br>Environment classes : M2 / E2<br>Temperature range : -40 °C / +70 °C<br>Further properties are described in the annexes:<br>- Description T11172 revision 2;<br>- Documentation folder T11172-1. |
| Valid until          | 1 September 2027   |
| Remarks              | This revision replaces the earlier version, except for its documentation folder.   |

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
14 November 2017



C. Oosterman  
Head Certification Board