


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis + Gyr A.E. 78th km National Road Athens-Corinth GR-201 00, Corinth Greece
Measuring instrument	A static Active Electrical Energy Meter Type : E450 ZCXi1x0 (E450) ZCX110 and ZCX120 Manufacturer's mark or name : Landis + Gyr Reference voltage : 230 V Reference current : 5 A or 10 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T11173 revision 2; - Documentation folder T11173-1.
Valid until	1 September 2027
Remarks	This revision replaces the earlier version, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
14 November 2017



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.