

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer AEM S.A.  
Piata General Gheorghe Domasnean nr. 5  
300693 TIMISOARA  
Romania

Measuring instrument A static **Active Electrical Energy Meter**

Type	: iCSM0601
Manufacturer's mark or name	: AEM
Reference voltage	: 230 V
Reference current	: 5 or 10 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:  
– Description T11189 revision 0;  
– Documentation folder T11189-1.

Valid until 8 October 2029

Issuing Authority

**NMI Certin B.V., Notified Body number 0122**  
8 October 2019

  
C. Oosterman  
Head Certification Board