

EU-type examination certificate

Number **T11193** revision 0 Project number 1901495 Page 1 of 1

Issued by NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Bernecker Engineering

Fichtenstrasse 16 4611 Buchkirchen

Austria

Measuring instrument A static Active Electrical Energy Meter

Type : MPM3C, MPM3P

Reference voltage : 3x230/400 V Reference current : 5 or 10 A

Destined for the measurement of : electrical energy, in a

- three-phase four-wire network

Accuracy class : A or B Environment classes : M1 / E2

Temperature range : -25 °C/+55 °C

Further properties are described in the annexes:

Description T11193 revision 0;Documentation folder T11193-1

Valid until 11 September 2027

Issuing Authority NMi Certin B.V., Notified Body number 0122

11 September 2017

C. Oosterman

Head Certification Board

NMi Certin B.V. Hugo de Grootplein 1

Hugo de Grootplein 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http://ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

