

EU-type examination certificate

Number **T11217** revision 0 Project number 1901644 Page 1 of 1

Issued by Manufacturer	NMi Certin B.V., designated and notified by the Net conformity modules mentioned in having established that the Measu requirements of Directive 2014/32 Elster Rometrics S.R.L. Sat Giarmata, Comuna Giarmata, DJ 691 KM8+775M Dreapta, Timisoara Airport Park, Judet Timi România	n article uring ir /EU, to	e 17 of Directive 2014 Instrument meets the a	/32/EU, aft		
Measuring instrument	A static Active Electrical Energy Type	/ Mete	er AS2020			
	Manufacturer's mark or name	+ +	Elster or Honeywell			
	Reference voltage	+ ÷.	3x230/400 V			
			230 V+ + + + +			
	Reference current + + + + +	+ $+$	5 A or 10 A (DC)			
			1 A (CT) + + +			
	Destined for the measurement of	+ ÷	electrical energy, in a		- + -	
			 three-phase four-w single-phase two-w 			
	Accuracy class	+ +	A or B	+ + + +	+	
	Environment classes	+ +	M1 / E2 + + + +			
	Temperature range	+ +	-40 °C / +70 °C			
	Protection class	+ +	IP54 + + + + +			
	Further properties are described in – Description T11217 revision 0;	n the a	nnexes:			
	- Documentation folder T11217-1	· + · +				
* Valid until	1 February 2028					
+ + + + + + + + + +	+ + + + + + + + + + + + +					
+ Issuing Authority	NMi Certin B.V., Notified Body	numb	oer 0122 + + + + +			
	1 February 2018					
+ + + + + + + + + + + + + + + + + + +	C. Øosterman					
+ + + + + + + + + + + + + + + + + + + +	Head Certification Board					
NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 63322322 certin@nmi.nl	This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability. The designation of NMi Certin B.V. as Notified				FCTION	
+ www.nmi.nl + + + + + + + + + + + + + + + + + + +	Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/		uction of the complete ent only is permitted.	RvA	1122	