

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer NRKsM
Pondweg 7
2153 PK Nieuw-Vennep
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**
Type : Ex9EMS 3P 4M CT 2T, Ex9EMS 3P 4M CT MB 2T and Ex9EMS 3P 4M CT MO 2T

Manufacturer's mark or name : NRKsM

Reference voltage : 3x230/400 V

Reference current : 1,5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -25 °C / +70 °C

Further properties are described in the annexes:

- Description T11261 revision 2;
- Documentation folder T11261-3.

Valid until 19 January 2028

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
6 January 2023

Certification Board