





Number T11302 revision 3 Project number 3567696 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Shenzhen Kaifa Technology (Chengdu) Co., Ltd.

No. 99 Tianquan Rd.,

Hi-Tech Development Zone

Chenadu 611731

P.R. China

Measuring instrument A static Active Electrical Energy Meter

MA304H4CNL or MA304 Type

KAIFA Manufacturer's mark or name

Reference voltage 3x230/400 V

Reference current 5 A

Destined for the measurement of electrical energy, in a

- three-phase four-wire system

Accuracy class A or B **Environment classes** M1 / E2 -25 °C / +70 °C Temperature range

Further properties are described in the annexes:

- Description T11302 revision 3;

- Documentation folder T11302-4.

Valid until 29 May 2028

Remark This revision replaces the earlier version, including its documentation folder.

## Issuing Authority

## NMi Certin B.V., Notified Body number 0122

11 November 2022

## **Certification Board**

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T+31 88 636 2332 certin@nmi.nl www.nmi.nl

