M	E U - t y p	e examination certificate
		Number <b>T11312</b> revision 1 Project number 2523392 Page 1 of 1
Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:	
Manufacturer	Shenzhen Kaifa Technology (Chengdu) Co., Ltd. No.1218 Hezuo Rd., Hi-Tech Development Zone (West) Chengdu P.R. China	
Measuring instrument	A static <b>Active Electrical Energy</b> Type	Meter : MA309T4GIL MA309T4RIL
	Reference voltage	: 3x230/400 V
	Reference current	: 5 A
	Destined for the measurement of	: electrical energy, in a - three-phase four-wire network
	Accuracy class	: A or B or C
	Environment classes	: M1 / E2
	Temperature range	: -25 °C / +70 °C
	Further properties are described in Description T11312 revision 1; – Documentation folder T11312-2.	the annexes:
Valid until	29 May 2028	

Issuing Authority



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl NMi Certin B.V., Notified Body number 0122 31 March 2021

## **Certification Board**

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

