

EU-type examination certificate

(\bullet)

Number **T11322** revision 3 Project number 3467418 Page 1 of 1

Ŧ	Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:		
	Manufacturer	EDMI Europe Limited UK Form 1, 17 Bartley Wood Business Bartley Way Hook, Hampshire RG27 9XA United Kingdom	Park	
	Measuring instrument	A static Active Electrical Energy Meter		
		Туре	:	ES-30B
		Manufacturer's mark or name	:	EDMI
		Reference voltage	:	3x230/400 V
		Reference current	:	5 A
		Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network - two-phase three-wire network
		Accuracy class		В
		Environment classes		M1 / E2
		Temperature range	:	-25 °C / +55 °C
		Further properties are described in the annexes: – Description T11322 revision 3; – Documentation folder T11322-3.		
	Valid until	30 October 2030		
	Remark	This revision replaces the previous versions, including for its documentation folder.		

Issuing Authority



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl NMi Certin B.V., Notified Body number 0122 11 January 2022

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

