

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr  
78km National Road Athens  
Corinth GR-20100  
Greece

Authorised representative Landis+Gyr Oy  
Paperitehtaankatu 9  
FI-40100 Jyväskylä  
Finland

Measuring instrument A static **Active Electrical Energy Meter**

Type	: E360-AM3D... (S1)
Manufacturer's mark or name	: Landis+Gyr
Reference voltage	: 3x230/400 V
Reference current	: 5 A or 10 A
Destined for the measurement of	: electrical energy, in a <ul style="list-style-type: none"><li>- three-phase four-wire network</li><li>- two-phase three-wire network</li><li>- single-phase two-wire network</li></ul>
Accuracy class	: B or A
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:  
– Description T11558 revision 22;  
– Documentation folder T11558-4.

Initially issued 12 December 2019

Valid until 12 December 2029

Remark This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
14 february 2024

Certification Board