

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer EDM I LIMITED
47 Yishun Industrial Park A
768724 Singapore

Measuring instrument A static **Active Electrical Energy Meter**
Type : Mk10M (Direct connected meter)
Mk10M (Transformer connected meter)
Mk6M (Transformer connected)

Manufacturer's mark or name : EDM I

Reference voltage : 3x57/100V or 3x240/415 V or
3x230/400 V

Reference current : 5 A (DC) or
1 A (CT)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B (DC)
C (CT)

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11583 revision 5;
- Documentation folder T11583-4.

Valid until 11 October 2029

Initially issued 11 October 2019

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
17 November 2023

Certification Board