

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer ZTE Corporation
NO.55 Hi-Tech Road South
NanShan District
Shenzhen City, Guangdong Province, P.R.China

Measuring instrument A static **Active Electrical Energy Meter**
Type : ZX AE220
Manufacturer's mark or name : ZTE Corporation
Reference voltage : 3x220/380V, 3x230/400V,
3x240/415V
Reference current : 5A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
- Description T11613 revision 0
- Documentation folder T11613-1

Valid until 19 July 2029

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
19 July 2019


C. Oosterman
Head Certification Board