

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Bemko Sp. z o. o.
ul. Bocznicowa 13
05-850 Jawczyce
Poland

Measuring instrument A static **Active Electrical Energy Meter**
Type : SL030-M-MID (A), SL03B-MID-M (A)
SL03A-MID (D), SL03B-MID.... (D, D-
CT, MODBUS, MBUS)
SL03A-MBUS-MID (C-CT)

Manufacturer's mark or name : Bemko Sp. z o. o.

Reference voltage : 3x230/400 V

Reference current : 5 or 10 A (SL030-M-MID (A), SL03B-
MID-M (A), SL03A-MID (D), SL03B-
MID.... (D-CT)
10 A (SL03A-MBUS-MID(C))
1,5 A (SL03A-MBUS-MID (C-CT),
SL03B-MID.... (D-CT)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:

- Description T11952 revision 1;
- Documentation folder T11952-2.

Valid until 17 September 2030
Initially issued 17 September 2020

Remarks This revision replaces the earlier version(s), including its documentation
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
17 May 2023

Certification Board