

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument A static **Active Electrical Energy Meter**

Type	: E360-AMxD...S1
Manufacturer's mark or name	: Landis+Gyr
Reference voltage	: 3x230/400 V
Reference current	: 1A or 5A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network
Accuracy class	: B or A
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12089 revision 3;
- Documentation folder T12089-2.

Valid until 6 May 2031

Remark This revision replaces the earlier version, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
3 December 2021

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.