

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Schneider Electric Industries SAS
Avenue Raymond Chanas, 5
F – 38320 Eybens
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : iEM2435 / iEM2455
Manufacturer's mark or name : Schneider Electric
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T12314 revision 2;
– Documentation folder T12314-2.

Valid until 12 April 2032

Initially issued 12 April 2022

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
13 July 2023

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.