





Number T12393 revision 0 Project number 3510327 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV

Pondweg 7

2153 PK Nieuw Vennep

The Netherlands

Measuring instrument A static Active Electrical Energy Meter

: DZT 6002 Series Type

Manufacturer's mark or name Inepro

Reference voltage 230 V Reference current 5 A

Destined for the measurement of electrical energy, in a

- single-phase two-wire network

Accuracy class : A or B **Environment classes** M1 / E2

Temperature range -25 °C / +55 °C

Further properties are described in the annexes:

- Description T12393 revision 0;

- Documentation folder T12393-1.

Valid until 25 May 2032



Issuing Authority

NMi Certin B.V., Notified Body number 0122 25 May 2022



Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T+31 88 636 2332 certin@nmi.nl www.nmi.nl



The designation of NMi Certin B.V. as Notified