	NM ^t)	E U - t y p e	•	examination
				certificate
				Number T12457 revision 0 Project number 3510425 Page 1 of 1
•	Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:		
	Manufacturer	EDMI Limited 47 Yishun Industrial Park A Singapore 768724		
	Measuring instrument	A static Active Electrical Energy Meter Type : Mk7Mi		
		Manufacturer's mark or name	: E	DMI Limited
		Reference voltage Reference current Destined for the measurement of Accuracy class	: 5 : e -	20-240 V A lectrical energy, in a single-phase two-wire network or A
		Environment classes		11 / E2
	(-	FTemperature range	: -4	40 °C / +70 °C
		urther properties are described in the annexes: Description T12457 revision 0; Documentation folder T12457-1.		
	Valid until	22 August 2033		
	Initially issued	22 August 2023		

Issuing Authority

NMi Certin B.V.

The Netherlands

T +31 88 636 2332 certin@nmi.nl

Thijsseweg 11

2629 JA Delft

www.nmi.nl

NMi Certin B.V., Notified Body number 0122 22 August 2023

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

