



# EU-type examination certificate

Number **T10329** revision 20  
Project number 4037405  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2014/32/EU, to:

Manufacturer

SAGEMCOM ENERGY & TELECOM SAS  
4 ALLEE DES MESSAGERIES  
92270 BOIS-COLOMBES  
France

Measuring instrument

A static **Active Electrical Energy Meter**

Type : CX1000-6 SL (CX1000-6 EDP  
STREETLIGHTING) and CX1000-6 S

Manufacturer's mark or name : SAGEMCOM ENERGY & TELECOM  
SAS

Reference voltage : 127 V or 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10329 revision 20;
- Documentation folder T10329-8.

Valid until

29 November 2030

Initially issued

29 November 2010

Remarks

This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
29 December 2025

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

