

EU-type examination certificate

Number **T10359** revision 27
Project number 4112488
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU,
after having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer

ABB S.p.A.
Viale dell'Industria 18
20009 Vittuone (MI)
Italy

Measuring instrument

A static **Active Electrical Energy Meter**

Type : A43, A44 and A44 690V

Manufacturer's mark or name : ABB

Reference voltage : 3x57,7/100V...3x288/500V (3-phase 4-wire network)
3x100V...3x500V (3-phase 3-wire network)
3x57,7/100V...3x400/690V (3-phase 4 wire network)
3x100V...3x690V (3-phase 3-wire network)

Reference current : A43: 5 A (direct connected)
A44: 1 A (indirect connected)
A44 690V: 1 A (indirect connected)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network

Accuracy class : A43: A or B
A44: A, B or C
A44 690V: A, B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10359 revision 27;
- Documentation folder T10359-15.

Initially issued

23 February 2012

Valid until

23 February 2032

Remark

This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
18 June 2026

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no
liability is accepted and that the manufacturer shall
indemnify third-party liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at
<https://webgate.ec.europa.eu/single-market-compliance-space/home>

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.