



# EU-type examination certificate

Number **T10542** revision 66  
Project number 4068708  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Kamstrup A/S  
Industrivej 28, Stilling  
DK-8660 Skanderborg  
Denmark

Measuring instrument

A static **Active Electrical Energy Meter**

Type : 685-2xx (Kamstrup 251Cx5)  
685-3xx (Kamstrup 351Cx5)  
685-4xx (Kamstrup 451Cx5)  
685-11x-xx-D-x (OMNIPOWER CT var 1  
and var 2)

Manufacturer's mark or name : Kamstrup

Reference voltage : 3x230/400V or 3x230V

Reference current : 1 A or 5A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network

Accuracy class : B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10542 revision 66;
- Documentation folder T10542-8.

Valid until

15 March 2033

Initially issued

15 March 2013

Remarks

This revision replaces the earlier versions, except for its documentation  
folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
22 January 2026

Certification Board

**NMi Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

