

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer METER&CONTROL d.o.o.
Veljka Dugoševića 54
11050 Belgrade
Serbia

Measuring instrument **A static Active Electrical Energy Meter**

Type : ST40xD (direct connected meter)
ST40xC (transformer connected meter)

Manufacturer's mark or name : METER&CONTROL d.o.o.

Reference voltage : 3x230/400 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : ST40xD: A or B
ST40xC: B or C

Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T10629 revision 23;
– Documentation folder T10629-13.

Initially issued 18 September 2015

Valid until 18 September 2025

Remark This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
13 June 2024

Certification Board