





Number **T10677** revision 13 Project number 3851707 Page 1 of 1

Issued by NMi Certin B.V.,

designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV

Pondweg 7

2153 PK Nieuw Vennep

The Netherlands

Measuring instrument A static Active Electrical Energy Meter

Type : PRO380 (-S,-Mb,-Mod)

Reference voltage : 3x230/400 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a

three-phase four-wire networkthree-phase three-wire networksingle-phase two-wire network

Accuracy class : B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10677 revision 13;

- Documentation folder T10677-9.

Valid until 9 December 2034

Initially issued 9 December 2014

Remark This revision replaces the earlier versions, except for its documentation

folder.

**Issuing Authority** 

NMi Certin B.V., Notified Body number 0122

9 December 2024

**Certification Board** 

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http://ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





