



EU-type examination certificate

Number **T10701** revision 22

Project number 3988487

Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect
to conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument

A static **Active Electrical Energy Meter**

Type

: 83334-1XXXXX, 83344-1XXXXX,
84334-1XXXXX, 84344-1XXXXX

Manufacturer's mark or name

: Networked Energy Services (NES)

Reference voltage

: 120 V ... 240 V

Reference current

: 5 A, 10 A or 20 A

Destined for the measurement of

: electrical energy, in a
- single-phase two-wire network

Accuracy class

: B or C

Environment classes

: M1 / E2

Temperature range

: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10701 revision 22;
- Documentation folder T10701-9.

Valid until

15 July 2035

Initially issued

15 July 2015

Remarks

This revision replaces the earlier versions, including its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122

8 January 2026

Certification Board

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

