

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.L
Via Robattino 54
20134 Milano
Italia

Measuring instrument A static **Active Electrical Energy Meter**

Type	: GEMIS
Manufacturer's mark or name	: Gridspertise S.r.L
Reference voltage	: 230 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: B or A
Environment classes	: M1 / E2
Temperature range	: -25 °C / +55 °C
IP rating	: IP 54

Further properties are described in the annexes:
– Description T10826 revision 30;
– Documentation folder T10826-14.

Valid until 1 September 2026

Initially issued 1 September 2016

Remark This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
1 March 2024

Certification Board