



EU-type examination certificate

Number **T11028** revision 16
Project number 4017441
Page 1 of 1

Issued by

NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

MetCom Solutions GmbH
Marie-Curie-Strasse 19
D-68219 Mannheim
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type : MCS301 and MCS501
Manufacturer's mark or name : MetCom
Reference voltage : 3x58/100 V, 3x230/400 V or
3x58/100 V 3x240/415 V or
3x58/100 V 3x277/480 V or
3x100 V ... 3x240 V or
3x230V/400V ... 3x415/720V
3x400/690V (Aux Power)
Reference current : 1 A or 5 A (CT version)
5 A or 10 A (DC version)
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network
Accuracy class : A or B (DC version)
B or C (CT version)
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
- Description T11028 revision 16
- Documentation folder T11028-12

Valid until

16 October 2027

Initially issued

16 October 2017

Remarks

This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
3 October 2025

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

