



## EU-type examination certificate



Number T11231 revision 6 Project number 3834884 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer **EDMI LIMITED** 

47 Yishun Industrial Park A

Singapore 768724

Authorised **EDMI Europe Limited** 

representative 17 Bartley Wood Business Park, Bartley Way

**RG27 9XA Hook Hampshire** 

**United Kingdom** 

Measuring instrument A static Active Electrical Energy Meter

ES-10B, ES-12B or ES-10C Type

Manufacturer's mark or name **EDMI** 

Reference voltage 230 V

5 A Reference current

Destined for the measurement of : electrical energy, in a

- single-phase two-wire network

Accuracy class : A or B

**Environment classes** M1 / E2

Temperature range -25 °C / +55 °C

Further properties are described in the annexes:

- Description T11231 revision 6;

- Documentation folder T11231-6.

Valid until 21 December 2028

Initially issued 21 December 2018

Remark This revision replaces the earlier versions, including its documentation

folder.

NMi Certin B.V., Notified Body number 0122 Issuing Authority 5 December 2024

**Certification Board** 

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ this certificate.

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

