





Number T11471 revision 25 Project number 4007689 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable

requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.L

Via Ombrone, 2 00198 Roma

Italia

Measuring instrument A static Active Electrical Energy Meter

Type GESIS

Manufacturer's mark or name Gridspertise

Reference voltage 3x230/400 V

3x127/220 ... 3x230/400 V

Reference current

Destined for the measurement of electrical energy, in a

- three-phase four-wire network

Accuracy class B or A **Environment classes** M1 / E2

Temperature range -25 °C / +55 °C

Further properties are described in the annexes;

- Description T11471 revision 25; - Documentation folder T11471-9.

Valid until 19 December 2028

Initially issued 19 December 2018

Remark This revision replaces the previous versions, including its documentation

folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122

18 November 2025

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl

www.nmi.nl

The designation of NMi Certin B.V. as Notified