

## EU-type examination certificate

## $( \bullet )$

Number **T11842** revision 11 Project number 3770264 Page 1 of 1

+	Issued by	conformity modules mentio	ed by the Netherlands to perform tasks with respect to entioned in article 17 of Directive 2014/32/EU, after t the Measuring instrument meets the applicable tive 2014/32/EU, to:				
	Manufacturer	Aidon Oy Piippukatu 11 FIN-40100 JYVÄSKYLÄ FINLAND					
	Mossuring instrument	A static Active Electrical E	noray M	oto			
	measuring instrument	Type		:	7534 (DC meter) and 7550 (CT meter)		
		Manufacturer's mark or nar	me	:	Aidon		
		Reference voltage Reference current Destined for the measurem Accuracy class Environment classes Temperature range Further properties are descr – Description T11842 revisio – Documentation folder T1	ribed in th on 11.	:	3x230/400 V 5 A (7534) and 1 A (7550) electrical energy, in a - three-phase four-wire network B (7534) and C (7550) M1 / E2 -40 °C / +70 °C		
	Valid until	22 July 2030					
	Initially issued	22 July 2020					
	Remark	This revision replaces the previous versions, including its documentation folder.					

Issuing Authority



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

## NMi Certin B.V., Notified Body number 0122 19 March 2024

## **Certification Board**

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

