

Issued by NMI Certin B.V.,
 designated and notified by the Netherlands to perform tasks with respect to
 conformity assessment procedures mentioned in article 17 of Directive
 2014/32/EU, after having established that the measuring instrument meets
 the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr Olympus AG
 Alte Steinhauserstrasse 18
 CH-6330 Cham
 Switzerland

Measuring instrument A static **Active Electrical Energy Meter**

Type : E660-A...S1 and E660-A...S2

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x58/100V - 3x240/415V - 3x277/480V
 (3p/4w)
 3x100V – 3x480V (3p/3w)

Reference current : 1 or 5 A

Destined for the measurement of : electrical energy, in a
 - three-phase four-wire network
 - three-phase three-wire network
 - two-phase three-wire network
 - single-phase two-wire network

Accuracy class : B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
 – Description T11845 revision 15;
 – Documentation folder T11845-7.

Valid until 18 June 2030

Initially issued 18 June 2020

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
 15 May 2026

Certification Board