



# EU-type examination certificate

Number **T11875** revision 28  
Project number 3972400  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Kamstrup A/S  
Industrivej 28, Stilling  
DK-8660 Skanderborg  
Denmark

Measuring instrument

A static **Active Electrical Energy Meter**

Type	:	OMNIA e-meter three-phase
Manufacturer's mark or name	:	Kamstrup
Reference voltage	:	3x230/400V, 2x230/400V, 230V 3x240/415V, 2x240/415V, 240V
Reference current	:	5 A or 10 A
Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network - two-phase three-wire network - single-phase two-wire network
Accuracy class	:	A or B
Environment classes	:	M1 / E2
Temperature range	:	-40 °C / +70 °C

Further properties are described in the annexes:

- Description T11875 revision 28;
- Documentation folder T11875-10.

Initially issued

31 March 2020

Valid until

31 March 2030

Remark

This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
19 December 2025

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

