

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
Denmark

Measuring instrument A static **Active Electrical Energy Meter**

Type : OMNIA e-meter three-phase

Manufacturer's mark or name : Kamstrup

Reference voltage : 3x230/400V, 2x230/400V, 230V
3x240/415V, 2x240/415V, 240V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T11875 revision 29
– Documentation folder T11875-11

Valid until 31 March 2030

Initially issued 31 March 2020

Remarks This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
6 March 2026

Certification Board