

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78th km National Road Athens-Corinth
Corinth GR-201 00
Greece

Authorised representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument A static **Active Electrical Energy Meter**

Type : E450 ZMXi3x0xQ... S5

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x230/400V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- two-phase three-wire network
- one-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11968 revision 11;
- Documentation folder T11968-7.

Valid until 27 October 2030

Initially issued 27 October 2020

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
14 November 2024

Certification Board