

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument A static **Single Phase Active Electrical Energy Meter**
Type : E360-AD2D...S2 or E360-AB3D...S2
Manufacturer's mark or name : Landis+Gyr
Reference voltage : 230 V
Reference current : 5 A or 10 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T12420 revision 10;
– Documentation folder T12420-6.

Initially issued 4 January 2023

Valid until 4 January 2033

Remark This revision replaces the previous versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
10 December 2024

Certification Board