

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised Representative

Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument **A static poly phase electricity meter**

Type : E360 AZ3D...B2
Manufacturer's mark or name : Landis+Gyr
Reference voltage : 3x230/400 V
Reference current : 10 A
Destined for the measurement of : electrical energy, in a
- three-phase-four-wire network
- three-phase-three-wire network
- two-phase-three-wire network
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -25 °C / +70 °C

Further properties are described in the annexes:

- Description T12517 revision 7;
- Documentation folder T12517-3.

Valid until

20 January 2033

Initially issued

20 January 2023

Remark

This revision replaces the previous version, excluding its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
04 July 2024

Certification Board