

EU-type examination certificate

Number **T12544** revision 3
Project number 4004444
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect
to conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Easee IP AS
Vassbotnen 23
4033 Stavanger
Norway

Measuring instrument

A static **Active Electrical Energy Meter integrated in an EV Charging
System**

Type : Charge Max
Charge Pro

Manufacturer's mark or name : Easee IP AS

Reference voltage : 3x230/400 V, 3x230 V and 230 V

Reference current : 6 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +55 °C

Further properties are described in the annexes:

- Description T12544 revision 3;
- Documentation folder T12544-2.

Valid until

22 July 2034

Initially issued

22 July 2024

Remark

This revision replaces the earlier versions, excluding its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
4 November 2025

Certification Board